

Prepared for: John Hornsby

Phone number: 214-668-6169

Address: 2526 Gerald Drive, Galveston 77551

Date: January 7

Inspection Date: January 3

## **BULKHEAD & PIER INSPECTION - 130'**

Concrete Bulkhead inspection - concrete panels and steel I beam are performing as they should, cosmetic signs of age but no imperative signs to the performance of the bulkhead.

Soil shows minimal signs of erosion from run off caused by rain due to slope of yard and sandy soil conditions but show no effect on bulkhead performance.

Concrete cap shows signs of cracks not caused by bulkhead, cracks appear to be from salt air and water penetrating into concrete and causing rebar to expand, concrete cap is cosmetic and not imperative to bulkhead performance

Dock pilings, lumber, and hardware are all satisfactory and performing with minimal signs of age

CUSTOMER SIGNATURE: X\_\_\_\_\_ DATE: X\_\_\_\_\_

HTM SIGNATURE: X\_\_\_\_\_ DATE: X\_\_\_\_\_