

Transferee / Property / Inspection Information

Transferee Name:	<u>Ralph Adams, Jr</u>	Street Address:	<u>3319 Aberdeen Way</u>
City:	<u>Houston</u>	State / Zip Code:	<u>TX / 77025</u>
Customer:	<u>NuCompass Mobility Services</u>	File Number:	<u>TXUE180051</u>
Customer Contact:	<u>Martha Brock</u>	Inspection / Report Date:	<u>7-5-2018 / 7-10-2018</u>

Issues Identified During Inspection

As per your request, a Hydrostatic Inspection was conducted at the above captioned property. The following was observed:

1. No repairs are necessary at this time.

Action Required

Action Required: 1. No repairs are necessary at this time.

If you have any questions or concerns, please do not hesitate to contact us.

Sincerely,

Kelly Boak
Senior Inspection Specialist
ReloOlogy Inspection Management Services
Phone: 215/622-4696



Mammoth Plumbing

3720 Greenhouse Rd | Houston, Texas 77084 |
281-398-1700 | admin@mammothplumbing.com |
www.MammothPlumbing.com

RECIPIENT:

Ralph Adams

3319 Aberdeen Way
Houston, Texas 77025
Phone: 832-651-8166

Invoice #17381

Issued	07/03/2018
Due	07/03/2018
Paid	07/03/2018

Total

Account Balance

For Services Rendered

SERVICE / PRODUCT	DESCRIPTION	QTY.	UNIT COST	TOTAL
07/05/2018				
Hydro static Test	<p>Description of work performed Hydro static test on sanitary sewer system</p> <p>Upon arrival, performed a walk through on property. Located sewer main clean out at side of property near HVAC equipment. Pulled water closet in hall bath downstairs and set aside. Placed test ball in clean out upstream towards exterior beam and began to fill using water closet flange to monitor water level. Monitored water level for a period of 20 minutes. Water level was stable indicating no leaks on the sanitary sewer system below structure at this time. Reset water closet with new wax ring and closet bolts. Sealed base of water closet with silicone.</p>			

** 2% transaction fee on all debit & Credit card payments**

*TEXAS STATE BOARD OF PLUMBING EXAMINERS | P.O BOX 4200,
AUSTIN, TX 78765 | PHONE: 512.458.2145 EXT 227 *
MPL #M36767
