

Joe Nettles Plumbing MPL #509
 10834 Warwana Rd.
 Houston, Tx. 77043

Invoice

Date	Invoice #
11/22/2017	39493

Phone #	Fax #
713-463-6080	713-463-6079



Bill To David Moore 10902 Memorial Dr Houston, Tx 77024		Ship To 	
P.O. Number	Terms	E-mail	Web Site
	Due on receipt	nettlesplumbing@att.net	nettlesplumbing.com

Item Code	Description	Amount
service	10/24/17 Performed static test on house sewer line under slab. There are five cleanout plugs, three in front, one on west side of house and one on east side by the garage. Tested all sewer lines under house, no leaks were found. Line was backing up when test was done; Ran sewer machine to clear stoppage; 10/30/17 Dug a hole by flower bed to check for leaks; Dug in the back of the house to find storm drain and make sure water drains, no issues were found Please note: Joe has checked the hole several times. He suggest you have your engineer check it and then let us know when you are ready for us to cover it up.	750.00
payment	12/06/17 paid with check #4764	-750.00

A \$25.00 charge will be added on all invoices not paid within 30 days from date of Invoice.

We accept all major credit cards, please contact our office to make payment by phone! All credit card payments will have an additional 3% fee to total invoice amount. A \$25.00 fee will be charged for Returned Checks.

Total	\$0.00
Payments/Credits	\$0.00
Balance Due	\$0.00

Thank you we appreciate your business!

Operates under Joe Nettles MPL #509 Texas State Board of Plumbing Examiners, 929 E. 41st St., Austin, Texas 78765 Ph: 512.458.2145/Fax: 512.450.0637/1.800.845.6594
