Fire Marshal's Division

2703 Veterans Dr Pearland, TX 77581

Fire Marshal's Office **Phone: 281-997-4650** **Fax: 281-997-4660**

Code Enforcement **Phone: 281-652-1766** **Fax: 281-997-4660**

Fire Inspection Notice-

Eustace and Mary Brown

2911 Helmsley DR
Pearland, TX 77584

An inspection of your facility on ***Monday March 19, 2018*** revealed the violations listed below.
ORDER TO COMPLY:

Since these conditions are contrary to law, you must correct them upon receipt of this notice.
An inspection to determine compliance with this Notice will be conducted on
at / / : : .

**If you fail to comply with this notice before the reinspection date listed, you may be liable for penalties provided for by law for such violations.*

Violation Code	Article	Division	Page	Count
200 FIRE EXTNGUISHERS			0	1
3A40BC FIRE EXTINGUISHER REQUIRED				
Repaired 03/19/2018				
1500 KITCHEN HOOD MAINTAINED			0	1
Kitchen hood cleaned and maintained				
Repaired 03/19/2018				

Notes:

Approved with Comments
Comments:

Fire extinguishers must be a minimum of 3A40BC.(Had 2x 1A10BC)
Must show proof of Residential Kitchen Suppression within 2 weeks.

Please take moment to complete our Quality Survey at www.cityofpearland.com/qualitysurvey

X _____
Prater, Shannon D
Inspector 03/19/2018 16:46

X _____
Mary Brown
Occupant/Owner