

INVOICE



Robert Uribe
airservicetechs@yahoo.com
281-777-0097

Bill to:

Brandon Crick
18819 Walden Forest Dr
Humble, TX 77346

Invoice No.: 06/17/2021
Invoice Date: 1163

Services

Complete AC system inspection of electrical componens, capacitors and freon pressures for 2 units good.
Drip pan shows signs of corrosion but no evidence of leaks in pan.
Everything in good working order.

Amount

\$ 120.00

Recommendations:

Drip pan replacement would be optional at this time.

Total \$ 120.00

THANK YOU FOR YOUR BUSINESS!!!