

Point Of Contact: Carlos -281-372-4532

INVOICE #:
DATE: 11/10/2021

TO:
WEDGEWOOD-INC

FOR: 4403 SARONG

Description	Amount
Hydro static Test- Performed by testing with a clean out on the left side of the property. The water was filled to the top of the clean out line. I waited 30 minutes to allow time to see if water would hold. Water held with no drop of level.	
Results of Hydro Static Test- PASSED	
	500.00
Total	\$500.00

Make all checks payable to Melara's Home Repair LLC
Payment is due upon completion of work/project.

THANK YOU FOR YOUR BUSINESS!