



# 2015 IECC Energy Efficiency Certificate

City of Houston



20115729

REVIEWED FOR COMPLIANCE  
Performance of this review does not relieve the applicant from full responsibility to comply with all applicable code and regulations.  
03/17/21

Insulation Rating	R-Value	
Above-Grade Wall	13.00	
Below-Grade Wall	0.00	
Floor	19.00	
Ceiling / Roof	30.00	
Ductwork (unconditioned spaces):	8.00	

  

Glass & Door Rating	U-Factor	SHGC
Window	0.40	0.25
Door	0.40	0.25

  

Heating & Cooling Equipment	Efficiency
Heating System: <u>Central Gas Furnace</u>	<u>80% AFUE</u>
Cooling System: <u>Split DX System</u>	<u>14 SEER</u>
Water Heater: _____	_____

Name: \_\_\_\_\_ Date: \_\_\_\_\_

Comments