



**Invoice**

**Ct mechanical**  
 8100 cypresswood  
 Spring Tx 77379  
 US

281-669-6955  
 Ctmechanicalaircon@gmail.com  
 Tax no. : 281-669-6955

**BILL TO**  
 John soto  
 8518 parapet pl. Rosharon TX 77583  
 Rosharon Tx 77583  
 (832) 576-3699

**Invoice #** 0065788  
**Date** 03/4/2022  
**Due date** 03/4/2022

Item	Quantity	Price	Amount
<b>Hvac inspection report</b> Complete hvac readiness inspection			
<b>Payment Instruction</b> Cash only Equipment deposit required before equipment can be ordered Paid in full via cash, Cashapp, Apple Pay		Subtotal	\$0.00
		Total	\$0.00

Amount Due **\$0.00**

OUTDOOR UNIT.

condensing section/compressor section and discharge pressures are within normal manufactures operating specs  
 compressor inrush amperage measured at 12.2 amps RLA measured at 2.4 amps both measurements are well within manufactures specs

#### INDOOR/EVAPORATOR SECTION

all pressures at evap coil within manufactures specs  
expansion device working within manufactures specs

#### FURNACE

burners all working within manufactures specs and shows no signs of cracking in the heat exchangers

#### INDOOR FAN MOTOR

INRUSH APERAGE: 16.6 amps

RLA: 5.6 amps

temperature split was neasured at 21.1 degrees between returns and supplys