

Hendricks Engineers, Inc.

Texas Engineering Firm Registration #F-002414
16000 Stuebner Airline, Suite 400
Spring, Texas 77379
281-374-8755

December 12, 2021

STRUCTURAL ENGINEER'S REPORT PIER INSPECTION AND COMPLIANCE REPORT

Location: 12626 Kingsride Lane
Houston, Texas 77024

Date of inspection: December 8, 2021


Client: Lisa Blackard
7622 Wedgewood Lane
Houston TX 77055

The purpose of this inspection was to determine if the drilled piers at the above referenced address were installed according to the plans and specifications developed by the Engineer.

On the date referenced above, a representative of Hendricks Engineers, Inc. inspected these piers to determine their location, size, and depth. Seven 12"x36" piers were drilled to a depth of 12'. The piers were reinforced with 4-#4 bars with #3 ties at 18" o.c.

It was found that the piers were installed correctly according to the Engineer's plans and specifications. The work was completed in substantial conformance to the Engineer's recommendations. Therefore, as indicated by my Professional Engineer's seal below, these piers have my approval.

Respectfully submitted,



Hendricks Engineers, Inc.
Bryan Hendricks, P.E.
President