



1205 W Carrier Pkwy  
Ste 205  
Grand Prairie TX 75050

info@blacktieplumbing.com  
www.blacktieplumbing.com

Toll Free: 888.973.3981  
Phone: 682.218.5777  
Fax: 682.218.5776

Tech: Jesus

Date: 11/11/19 Job#

Requested By:

Customer Name: Ana Laurel Staskus

Type of Test: Post-Test

Address: 1930 Shadowdale Dr

City: Houston

ZIP Code: 77043

Phone#: 361-648-3966

### Domestic Water Pressure Test

PSI at Start of test: 62 Location of Test Gauge:

PSI at End of test: 62 Total PSI Lost: 0 Length of test: 15 Min.

Pass  Fail  Unable to Test

For reference to this test Domestic Water Pressure Test is defined as: All water piping extending from the water meter, yard line and fixtures throughout the home. The test is performed by installing a gauge onto a hose bib utilizing the supplied city pressure and turning off the water at the meter. If a leak is indicated it could be a fixture drip, leak in the yard line, leak in the sprinkler system or a leak under the slab. If the system leaks we recommend a leak location test be performed to identify where the leak is in the domestic water system.

### Sewer Hydrostatic Test

Type of Cleanout: Single 2-Way Material Type: PVC Size of Cleanout: 4 Inch

Amount of Loss: 0 Length of test: 30 Min.

Pass  Fail  Unable to Test

Cleanout Location/Depth: left side corner 2' depth

For reference to this test Sewer Hydrostatic Test is defined as: All Sewer Piping extending from the cleanouts to under the Perimeter Beams of the Foundation of the Building. The test is performed by raising the cleanout to slab level, inserting a test ball into the sewer system and filling the sewer with water to slab level. If a leak is indicated we would recommend a leak location test be performed to identify where the leak/leaks are in the sewer system. Leak tests are accurate in most but not all cases. Before going through the expense of performing the leak locate have the sewer tested again. If you use Black Tie Plumbing to perform the leak locate and we identify there is no leak we will not charge you for the additional testing.

### Recommendations/Notes:

Customer Signature: \_\_\_\_\_

Tech: Jesus