

legend

IIO VOLT RECEPTACLE MP WATERPROOF RECEPTACLE **GET IIO VOLT W GROUND FAULT INTERRUPTOR** $\succ \ominus \dashv$ IIO PLUG STRIP (UNDER COUNTER) FLR. 110 VOLT IN FLOOR 220 VOLT RECEPTACLE TELEVISION ANTENNA TELEPHONE OUTLET SINGLE POLE SWITCH @38" A.F.F. THREE WAY SWITCH @38" A.F.F. FOUR WAY SWITCH @38" A.F.F. \$DIM DIMMER SWITCH PUSH BUTTON PUSH BUTTON SD SMOKE DETECTOR △ CD CARBON MONOXIDE DETECTOR CEILING MOUNTED LIGHT FIXTURE CEILING MOUNTED HANGING FIXTURE RECESSED CAN LIGHT LED OWP WATERPROOF RECESSED CAN LIGHT RECESSED EYEBALL SPOT LIGHT WALL MOUNTED LIGHT FIXTURE PORCELAIN FIXTURE W/ PULL CORD FLOOD LIGHTS EXHAUST FAN L.V. LIGHTS NETWORK DROP, ALLOW FOR TEL, CATV, CAT6 CEILING FAN CEILING FAN W/ LIGHT DNDER COUNTER LT. TRACK LIGHTS FLUORESCENT LIGHT PANEL

notes

WIRING AND BATTERY BACKUP. MULTIPLE UNITS SHALL BE INTERCONNECTED TO ACTIVATE ALL ALARMS. CONSULT MANUF. RECOMMENDATIONS FOR DISTANCE FROM R/A. LOCATION TO COMPLY WITH R313 IRC. - VENT ALL EXHAUST FANS TO OUTSIDE - PROVIDE G.F.I. PROTECTION AS REQ'D. - PROVIDE LIGHT FIXTURE AND SMOKE DETECTORS AT EACH WATER HEATER AND A/C UNIT LOCATION IN

- SMOKE DETECTORS REQUIRE 110Y CONNECTION TO HOUSE

- ALL CONSTRUCTION SHALL COMPLY W/ IRC 2012 & THE 2020 NEC.

- PROVIDE ELECTRIC DISCONNECT AT EACH A/C UNIT - ALLOW FOR 2 A/C UNITS - PROVIDE LOW VOLTAGE CIRCUITS FOR SECURITY

- PROVIDE CIRCUITS FOR FUTURE POOL AND REAR YARD LIGHTING

- ALL BEDROOMS BRANCH CIRCUITS MUST BE PROTECTED BY AN ARC-FAULT CIRCUIT INTERRUPTER AS PER THE

210-12 NEC.

- GFCI PROTECTION SHALL BE PROVIDED IN ACCORDANCE W ELEC. CODE 210.8 NEC.

- CARBON MONOXIDE COMPLY WITH UL 2034 AND IN ACCORDANCE WITH NFPA 720.

first floor electrical plan