



February 10, 2020


Building Official
City of LaMarque
Code Enforcement Division/ Structural Inspections
1111 Bayou Rd, La Marque
TX 77568 Katy, TX 77492
Attn: Chief Structural Inspector

Reference: 214 Bayou Rd. La Marque, TX 77561

Dear Sir/Mam:

This is to state that roof at the above referenced address is installed per Texas Windstorm Criteria of 120 mph 3 sec gust codes. If you should have any questions feel free to call me at 281-889-9634.

Sincerely,


Jason Henrichs, P.E.
JRH Engineering, Inc.
Firm Registration No. - 10385

