



Certificate of Compliance WPI-8

Location of Property to be Insured

Street: 3201 Avenue N

Block:

City: Galveston

Lot:

Tract or Addition:

County: GALVESTON

Inside City Limits

Design wind speed 150 mph

Seaward - International Building Code, 2018 Edition - Risk Category II

Date of Construction: 07-13-2022

Application ID: 2295076

Occupancy Type: Residential

Certificate Number: 2295076

Building Type: House

Roof Entire Re-Roof with Re-Decking August 11, 2022 Appointed Qualified Inspector Product Evaluation Report Number:
tainted Landmark shingles, ASTM D 3161 Class F, Certaineed XT 25 starter shingles, Flint Lastic Underlayment, 2 layers for low slope awning areas slope of roof is 5.5, r
rip edgegalvanized roof nails, Comments: Main roof 5.5 slope, awning areas are 3

This Certificate of Compliance, Form WPI-8, is issued by the Texas Department of Insurance under Insurance Code § 2210.251 and § 2210.2515 and demonstrates that the ongoing improvement identified in the certificate complies with the applicable windstorm building code under 28 Texas Administrative Code §§ 5.4007 – 5.4011.