



Certificate of Compliance WPI-8

Location of Property to be Insured

Street: 3201 Avenue N

Block:

City: Galveston

Lot:

Tract or Addition:

County: GALVESTON

Inside City Limits

Design wind speed 150 mph

Seaward - International Building Code, 2018 Edition - Risk Category II

Date of Construction: 09-02-2022

Application ID: 2305441

Occupancy Type: Residential

Certificate Number: 2305441

Building Type: House

Alterations Exterior Wall Covering (Siding) October 19, 2022 Appointed Qualified Inspector Location: Outside all 4 walls from to
ottom, Square Footage: 2200, Type (EX. Vinyl, Wood, Fiber, Cement): Hardi Plank fiber cement on the house siding and the bottom of the house is enclosed with Smart
ing with Weather Proofing tied into bottom framing studs and entire ground floor is tied together with hurricane clips, straps, and horizontal bracing between studs.

This Certificate of Compliance, Form WPI-8, is issued by the Texas Department of Insurance under Insurance Code § 2210.251 and § 2210.2515 and demonstrates that the ongoing improvement identified in the certificate complies with the applicable windstorm building code under 28 Texas Administrative Code §§ 5.4007 – 5.4011.