



Certificate of Compliance WPI-8

Location of Property to be Insured

Street: 3201 Avenue N

Block:

City: Galveston

Lot:

Tract or Addition:

County: GALVESTON

Inside City Limits

Design wind speed 150 mph

Seaward - International Building Code, 2018 Edition - Risk Category II

Date of Construction: 11-08-2022

Application ID: 2313549

Occupancy Type: Residential

Certificate Number: 2313549

Building Type: House

Alterations Replace Window(s) January 13, 2023 Appointed Qualified Inspector Number of Windows: 8, Location: 4 windows on the front of the house, 2 windows on the left side of the house (facing the front of house), 1 window on the back of the house and 1 window in the kitchen located on the left side of house, Impact: Non-Impact, Is Windborne Debris Protection Available On-Site: Yes, Product Evaluation Report Number: TDI Evaluation WIN 435, 35-1/2' x 71-1/2' Gly Ply 500, HPSC glass

This Certificate of Compliance, Form WPI-8, is issued by the Texas Department of Insurance under Insurance Code § 2210.251 and § 2210.2515 and demonstrates that the ongoing improvement identified in the certificate complies with the applicable windstorm building code under 28 Texas Administrative Code §§ 5.4007 – 5.4011.