

COOLING

Preventative Maintenance Service
 2 or more units price NO. Of units _____ Customer Approval _____

1. Inspect and adjust the blower and blower components
2. Check the unit for proper refrigerant charge (if low 1lb. free)
3. Check the voltage and amperage on the motors.
4. Check refrigerant lines for leaks.
5. Check for proper temperature drop.
6. Lubricate all moving parts on the unit.
7. Calibrate the thermostat.
8. Clean thermostat.
9. Check the electrical connections.
10. Check the safety controls for defects.
11. Check the condensate drain and lines.
12. Clean the pan and chemically treat it for algae growth if accessible.
13. Service the drain pump.
14. Check the starting capabilities.
15. Check the circuit breakers and fuses for proper size and defects.

THIS IS A PREVENTATIVE MAINTENANCE SERVICE ONLY

Any repairs will require additional charges on parts, labor and material
NO WARRANTY ON DRAIN LINES.

HEATING

1. Clean Pilot & Assembly
2. Check Heat Exchanger
3. Adjust Air and Gas Mixture
4. Set Blower Control
5. Set Gas Limit
6. Check Blower
7. Check fan Belt
8. Check all Safety Controls
9. Check Vent for obstructions
10. Lubricate Blower Motor and all moving parts
11. Check and Adjust for proper temperature rise
12. Change Filters if available
13. Check Vent Pipe for leaks
14. Check all electrical Connections
15. Check voltage for proper AMP draw
16. Check Heat Strip
17. Check the circuit breakers and fuses for proper size and defects.
18. Clean Thermostat
19. Calibrate Thermostat
20. Check for proper air flow HEAT PUMPS most of the above plus
21. Check Freon
22. Check unit for proper cycling and adjust if needed

Any repairs will require additional charges on parts, labor and material.

TO OUR CUSTOMERS

WE WANT YOUR BUSINESS. IF YOU ARE DISPLEASED IN ANY WAY WITH OUR PERFORMANCE, PLEASE CALL AND TELL US. WE WILL GLADLY DO OUR BEST TO REMEDY THE PROBLEM.

Regulated by TX Dept. of Licensing and Regulations
 P.O. Box 12157 • Austin, TX 78711
 1-800-803-9202 • 512-463-6599 • www.tdlr.texas.gov
 EQUIPMENT AND PART INSTALLATIONS DEEMED UNCOLLECTABLE ARE SUBJECT TO MECHANICAL AND MATERIAL LIEN.

MAILING ADDRESS
 502 W. Montgomery #548
 Willis, Texas 77378

936-228-0063 Office
 936-228-0431 Fax



24 HOUR EMERGENCY SERVICE
FREE ESTIMATES
RESIDENTIAL & COMMERCIAL
 www.tcsacandheat.com
 info@tcsacandheat.com

TACLBO15580E
 dba AIRCORP/T.C.S.

DATE 12/30/22
 PROMISED
 COMPLETED

-CUSTOMER- NAME Tim Pushor **-Service Man-** REMARKS Domingo
 ADDRESS 2230 Oak Circle Dr N.
 CITY Conroe, TX 77301
 SERVICE AGREEMENT YES NO
 PHONE 207-431-5125 EMAIL _____

QTY	PART NUMBER	MODEL	MATERIALS	SERIAL NUMBER	AMOUNT
			- Installed a wireless thermostat for master bedroom		
			- Replaced 12" motorized damper for master bedroom		
			- Adjusted static pressure regulator in bypass damper		
			- Installed a mixing box with manual dampers to control air flow to master suite		
			- Installed a safety float switch in secondary drain pan		
			- Primary drain line modifications		
			- Low voltage wirings		
			- Individual duct runs to master suite		
TOTAL					\$2,950.00

Recommendations & Additional Work RECOMMEND SAFETY FLOAT SWITCH FOR DRAIN PAN

Amazing team. Thank you Mr. Domingo for accurate advice and great service.

Customer Approval X _____ Recommended work not done at this time X _____