



Lords Chimney

A Division of Lords Services LLC

9539 Town Park Drive
Houston, TX 77036
281-497-4000

www.LordsChimney.com



Note: This document is a result of a visual inspection done at the time of cleaning. It is intended as a convenience to our customers, not as a certification of fire worthiness or safety. Since conditions of use and hidden construction defects are beyond our control, we make no warranty of the safety or functionality of any appliance and none is to be implied.
Not Responsible: for water damaged sheetrock or the repair of sheetrock and painting due to our work or our installation.

Customer Karen Funke
Address 16111 Elan Point Ct.
City Houston State TX Zip 77093
Phone _____
Alt Phone 972-955 8350
Alt Phone _____
Date 14 Nov 16 Key Map # _____
Sweep's Name Lee C. Smith #5928

Customer Verification

I have read this form and now understand which areas of my chimney system appear to be satisfactory and not satisfactory.

Signed Karen Funke Date _____
Next Appointment 23 Nov 16 (8-11)

Receipt / Invoice

Chimney Clean	=	129.33
Cap (1)	=	4500.00
(2)	=	1000.00
(3)	=	450.00
(4)	=	495.00
(5)	=	400.00
(6)	=	1426.00
Tax		10.67
SUB-TOTAL		8411.00
Deposit (Non-Refundable)		4000.00
Balance Due		4411.00
Check#	Amount	

A 35 dollar service charge will be applied to all returned checks.

Credit Card: Visa MasterCard
4313 0725 7347 8990
Security code 368 Exp. Date: 7/19

I, the home owner, am happy with the work completed and the worksite is cleaned up to my satisfaction.

Initial _____

How did customer hear about Lords?

Comments: Estimates Valid for 30 Day

- Smoke chamber & Flue fill mortar holes - Heat shield - 4500.00
- Backwall unstable - Rebuild & Dain - 1000.00
- Splay Cracked - Brown Coat - 450.00
- Exterior mortar holes Filled w/ caulking - Remove Caulking & Touch up w/ Preserv Wash - 495.00
- Waterproof Bush - 400.00
- 24" Chased out w/ electric ignition burner - 1426.00



*All estimates exclude painting, electrical, plumbing and extensive carpentry
*All labor warranted for ten year if maintained according to NFPA 211

INSPECTION PERFORMED

- None
- Level One
- Level Two

EMAIL ADDRESS:

40 Bush
Red metal
24"
13x13
8271