

CHECK LIST

Compressor Suction _____ PSI
 Head _____ PSI
 VOLTS _____ AMPS
 Electrical Connections
 Contacts Tight & Clean

Condenser Coil
 Clean Yes _____ No _____
 Fin Condition _____

Fan & Motor
 Volts _____
 Amps _____
 Electrical Connections
 Lube Components
 Fan Pulleys
 Adjust Belts

Evaporator Coil
 Clean Yes _____ No _____
 Temperature _____
 Diff. _____ ENT / LVG

Condensate Areas
 Prim. Pan _____
 Sec. Pan _____
 Drain lines _____

Air Filter
 Clean or Replaced _____
 Filter Size _____

Heating System
 Flue pipe _____
 Single _____ Double _____
 Gas line _____
 Heat Exch. _____
 Burner Assembly
 Standing Pilot or Elect.
 Blow Assembly
 Strip Heat _____
 Vots _____ Amps _____
 Blow Motor _____
 Gas Valve _____

Thermostat
 Replace or Relocate
 Location _____

Return Air
 Vial Chase _____
 Vial _____
 Had Flex Duct _____
 Had Flex Duct _____

Quantity	Item or Part Description	Price	Amount
----------	--------------------------	-------	--------

Everything is functioning properly had an R60 split between supply and return on both AC systems.

Thank you for your business. Please send payment Net 30 days, payment thereafter 1.5 percent monthly interest charge, and all additional collection cost.

Regulated by The Texas Department of Licensing and Regulation, P.O. Box 12157, Austin, Texas 77871, 1-800-803-9202, 512-463-6599

Davis & Son HVAC is not responsible for re-occurring water damage associated with repairs or modifications to existing systems.

Customer Signature: _____

Parts Warranty
 All parts as recorded are warranty as per manufacturer specifications.

Labor Warranty
 The labor charge as recorded here relative to the equipment serviced as noted, is guaranteed for a period of 30 days. We do not, of course, guaranty other parts than those we supply. If repairs later become necessary due to other defective parts, they will be charged separately.

Refrigerant Type _____
 System Pump Down QTY. _____
Recovery Required QTY. _____
Refrigerant Usable QTY. _____
Disposal of Refrigerant QTY. _____

System requires refrigerant line filtration be placed back into system.
 Suction _____ Liquid _____

Equipment
 Change Out or Replacement
 Dismantling Required Yes or No

Davis & Son HVAC, LLC
 131 Happy Hollow Street
 Alvin, Texas 77511
 713.504.8104
 "Your Indoor Air Quality Experts"
 TACLB208C

5367

Name David Gothard
Address 111 Yucca Ave
City Freeport **State** Tx **Zip** 77541
Phone: _____ **Wk. Phone** _____

Make	Model	Serial	Time Arrived	Time Departed	Call Type

Description Of Work	Price
AC Inspection 2-systems \$125 per system	\$250
2.5 Ton	
Downstairs - Condensers 2020-Air handler 2013	
2.5 Ton	
Upstairs - Condenser 2019-Air handler 2015	
Ducts & Connections ok	
Free leads ok	
Capacitors in spec	
Charged maindrains	

Technician Signature: *Yakov Bove*

I HAVE THE AUTHORITY TO ORDER THE ABOVE WORK AND DO SO ORDER AS OUTLINED ABOVE. IT IS AGREED THAT THE SELLER WILL RETAIN TITLE TO ANY EQUIPMENT OR MATERIAL FURNISHED UNTIL FINAL & COMPLETE PAYMENT IS MADE, AND IF SETTLEMENT IS NOT MADE AS AGREED, THE SELLER SHALL HAVE THE RIGHT TO REMOVE SAME AND THE SELLER WILL BE HELD HARMLESS FOR ANY DAMAGES RESULTING FROM THE REMOVAL THEREOF.

Authorized Signature _____

Sub-Total _____
Tax _____
Total Amount \$250.00

Above Ordered Work Has Been Completed and I Acknowledge Receipt Of My Copy
X. *Yakov Bove* **Date:** 5/30/23