

# NOTES



*2206 Manchester Lane*

## THE FOLLOWING REPAIRS MADE

- A/C SYSTEM
  - INSTALLED NEW OVERFLOW SWITCH
  - REPLACED BAD CAPACITOR
- ROOF
  - REPLACED ROOF JACK – SHINGLES
- PLUMBING
  - REPAIRED THE HOT WATER HEATER VENT PIPE
  - REPAIRED ALL DRAIN LINES FOR SLOW DRAINING SINKS
    - INCLUDING THE DISHWASHER
  - REPLACED WATER STOP IN ALL SINKS
- ELECTRIC
  - CHECKED ALL ELECTRICAL RECEPTACLES INSIDE/OUTSIDE
- OUTSIDE SHED
  - REPLACED ROTTEN FACIAL 1 X 4
  - REPLACED THE PAD LOCK WITH NEW LOCK/KEY
  - PAINT THE FRONT OF THE SHED