



1206 E. 13<sup>th</sup> Street  
Deer Park, Texas 77536  
(713)539-5795  
[gonzorepair@yahoo.com](mailto:gonzorepair@yahoo.com)

Jimmy Shatara

Property: 5803 Olympia Fields Lane  
Houston, Texas 77069

On June 23, 2023, Gonzo Foundation Repair inspected the above address foundation using ZIPLEVEL and according to the elevations on the drawing house is within 1 inch from zero, there is no cracks on bricks and sheetrock and all doors latch.

Contractor is recommending sprinkler system to water the foundation everyday at 4am for 10-15 minutes for best results. With doing this the foundation should level and bring house back to level. Home is not needing any foundation work at this time.

If you have any further questions, please do not hesitate to call.

Thank you,

Edward Gonzalez



Family owned and 20 years in business

1206 E. 13th Street  
Deer Park, Texas 77536

713-539-5795  
[gonzorepair@yahoo.com](mailto:gonzorepair@yahoo.com)  
[www.gonzofoundationrepair.com](http://www.gonzofoundationrepair.com)

## Invoice

Project address: \_\_\_\_\_ Date: 03-23-2022

Jimmy Shatara  
5803 Olympia Fields Lane  
Houston, Texas 77069

### Description

Invoice	Foundation Inspection		
		<b>TOTAL</b>	<b>\$ 300.00</b>



**Edward Gonzalez**  
(713) 539-5795

gonzorepair@yahoo.com

www.gonzofoundationrepair.com



Date: JUNE 23, 2023

Name: JIMMY SHATARA

5803 OLYMPIA FIELDS LN

Phone: 281-793-5460 Hou Tx 77069

# Piers Thru Dirt \_\_\_\_\_ @ \_\_\_\_\_ = \_\_\_\_\_  
 # Piers Thru Concrete \_\_\_\_\_ @ \_\_\_\_\_ = \_\_\_\_\_  
 # Interior Piers \_\_\_\_\_ @ \_\_\_\_\_ = \_\_\_\_\_  
 # Tunnel (ft) \_\_\_\_\_ @ \_\_\_\_\_ = \_\_\_\_\_  
 LEGEND: X - Piers Location (X) - Piers Concrete

P+B House \_\_\_\_\_  
 # of 4x6x12 \_\_\_\_\_  
 # of 2x6x10, 2x8x10, 2x10x10 & 2x10x12 \_\_\_\_\_  
 # of Sq. Ft. House \_\_\_\_\_

GUTTERS Gutters # \_\_\_\_\_ of ft 4" or 6"  
 Gutter guard # \_\_\_\_\_ of ft  
 Downspouts # \_\_\_\_\_ of ft

Permit Cost \_\_\_\_\_

Total Job Cost \_\_\_\_\_  
EMAIL LETTER RECOMM TO WATER

Drain/French Drain FOUNDATION  
 # of Feet NO PIERS NEEDED  
 4" Solid Pipe \_\_\_\_\_  
 6" / 9" / 12" Catch Basin \_\_\_\_\_

