

Posted 2/16/82
FEE 25.00

COMAL COUNTY SANITATION DEPARTMENT

RECEIPT NO. 45949

APPLICATION FOR HOUSEHOLD SEWAGE SYSTEM

NAME - LOCATION of Property where Sewage System is to be installed:

CANYON LAKE VILLAGE WEST

UNIT NO. 5 BLOCK NO. LOT NO. 587A STREET-ROAD NO. BARBARA, DRIVE

DIMENSION OF PROPERTY ? PERCOLATION RESULTS ATTACHED WAIVED

ZONE: RECHARGE RESTRICTED WATER QUALITY

+DESCRIPTION OF STRUCTURE AND SYSTEM+

NO. BEDROOMS 8 NO. BATHROOMS 8 DISPOSAL 8 WASHING MACHINE STUB OUT 507

SIZE OF SEPTIC TANK 2,250 NO. FT. LATERALS 2,000 OTHER C/W DATE: 6/10/81

IVAN PEYTON (OWNER) (SAME) CONTRACTOR

CANYON LAKE, TX (AS OWNER) ADDRESS 811-7608 ADDRESS 72190

**ALL recommendations are minimum suggestions as described in "CONSTRUCTION STANDARDS FOR PRIVATE SEWAGE FACILITIES," published by the TEXAS HEALTH DEPARTMENT, AUSTIN, TEXAS.

NOTE: FOR the information to be submitted in connection with this Application, see the requirements outlined in the current TEXAS WATER DEVELOPMENT BOARD RULES 156,20,05,001,019---COMAL COUNTY RESOLUTION 74-R-10.

SEWAGE FACILITIES: PERMIT NO. 45949 LOCATION Canyon Lake Village West, Barbara, Dr (Subdivision) (Street)

OWNER: (SAME AS ABOVE) (SAME AS ABOVE) ADDRESS

INSPECTED BY: J. Yander RS 1st. DATE 5 JAN 82 Final Date 12 FEB 82

PERMIT Granted for Period of 5 yrs Renewal Date 12 FEB 87

TRANSFER of PERMIT only thru Comal County Sanitation Department by New Owner for remaining period of Permit.