



APPROVED BY *Pw.*
FEB 10 1999
MTA INC.
FEDERAL MANUFACTURED HOME
 CONSTRUCTION AND SAFETY AUTHORITY

GENERAL NOTES:
 SHEARWALL & DIAPHRAM VALUES BASED
 ON 7'-6" SIDEWALL HEIGHT.
 WIND ZONES 1 & 2
 INSULATION PACKAGES:
 THERMAL ZONE 1 - 11/11/21 W/O STORMS
 THERMAL ZONE 2 - 22/11/21 WITH STORMS
 THERMAL ZONE 3 - 22/11/28 WITH STORMS
 22/19/21 WITH STORMS

TOTAL WINDOW AREA = 187.1 SQ. FT.
 TOTAL DOOR AREA = 41.6 SQ. FT.

ROOF DECKING TO BE USED AS SHEAR DIAPHRAM

- WIND ZONE I FORT WORTH PLANT 1
- SW #1 & #4 - 179 PLF - 11'-1" (MIN.)
- SW #1 & #4 - 210 PLF - 10'-0" (MIN.)
- SW #1 & #4 - 327 PLF - 7'-0" (MIN.)
- SW #1 & #4 - 350 PLF - 7'-0" (MIN.)
- SW #1 & #4 - 420 PLF - 6'-0" (MIN.)

- WIND ZONE II FORT WORTH PLANT 1
- SW #1 - 179 PLF - 13'-6" (MIN.)
- SW #2 - 327 PLF - 11'-4" (MIN.)
- SW #3 - 327 PLF - 8'-4" (MIN.)
- SW #4 - 179 PLF - 8'-0" (MIN.)

MODEL D7432A		DRAWN BY:	DATE:
		DAN	2-11-98
REVISION DESCRIPTION			
REVISED SHEARWALL LENGTHS	BY	MIKE	DATE
REVISED ROOF PRINTS FOR TRUS JOIST RIDGE BEAM.		MIKE	11-98
ADDED SWITCHED RECEPT./MADE LIGHT OPT. IN LIVING ROOM		MIKE	11-98
		MIKE	1-99

REVISION W71 179 DIF SHEARWALL