


Survey w/pool/metal building rendering



Design Summary:

- 3 Bedroom Home (over 2,500 sq. ft.)
- 300 GPD
- 0.041 application rate
- 7,318 sq. ft. spray area required
- 7,696 sq. ft. spray area designed
- Install 2 purple top spray heads
- Set timer to spray between 12 am and 5 am

Legend:

- C/O = 2-way sch 40 clean out
- Tanks =
500 gallon trash tank
500 gallon ATU
Chlorinator
750 gallon pump tank



Customer: Arrambide Residence	Section: 2	Designer: Ben Whitley
Address: 1746 Opal Trail	Block: 5	Phone: (936) 520-2092
City, State, Zip: Willis, TX 77378	Lot: 11	
Subdivision: Emerald Lakes	Acres: 1.52	
County: Montgomery		Scale 1" = 50'