



Mid County Ac and Heating

Matthew Tyer
515 Meadowcroft Lane
Winnie, TX 77665

(281) 731-4212
matt.tyer94@gmail.com

INVOICE	#6004
SERVICE DATE	May 07, 2024
DUE	Upon receipt
AMOUNT DUE	\$0.00

CONTACT US

611 N 28th St
Nederland , TX 77627

(409) 748-5585
Midcountyac@gmail.com

INVOICE

Services	qty	unit price	amount
A/C Service Call (Res) A service pro will come to your home to diagnose your Air Conditioner problem.	1.0	\$85.00	\$85.00
Materials	qty	unit price	amount
Performed inspection in HVAC system, checked both coils found clean , checked amperage's, checked temp split 57.2 degrees supply air . Run capacitor good, refrigerant charge good at 12 degrees sc . Found drain lines slight blocked . Cleared drain lines and primary drain pan .	1.0	\$85.00	\$85.00
Subtotal			\$170.00
Total Tax			\$6.80
Credit card Payment (4%)			\$6.80
Total			\$176.80

Payment History

May 07	Tue 2:10pm	Credit Card	\$176.80
--------	------------	-------------	----------

I have the authority to order the work outlined above which has been satisfactorily completed. I agree that the Seller retains title to equipment/materials furnished until final payment is made. If payment is not made as agreed, Seller can remove said equipment/materials at Sellers expense and/or impose a 2% liquidation fee on the entire amount contained in the Seller/Buyer transaction. Any damage resulting from said removal shall not be the responsibility of Seller. If payment is not made within 30 days a 10% fee will be added every 30 days.





RHEEM SALES COMPANY, INC.
Acondicionador de Aire Central
Modelo: RP1436AJ1NA
Tensión Nominal: ~ 208/230 V
Fases: 1
Frecuencia: 60 Hz
Corriente Nominal: 22/22 A
Requiere Tierra Física
ENSAMBLADO EN MÉXICO
Leer Manual de Instalación y Operación Anexo
92-22050-20-01








NOTES:

1. Use Copper Wire (75°C Min) Only Between Disconnect Switch And Unit.
2. To Be Wired In Accordance With Nec And Local Codes.
3. If Any Of The Original Wire, As Supplied, Must Be Replaced, Use The Same Or Equivalent Type Wire.
4. Use 60 Amp class K Fuses Only, For Replacement.



LABEL (3)

- UNIT BREAKER
- FU
- LINE FUSE
- GND EQUIPMENT GROUND
- HTR HEATER
- REC RECIPER
- TDR TIME DELAY RECIPER
- FIELD POWER WIRING
- MARKED TERMINAL
- PLUG AND RECEPTACLE

329613-101 REV. B

PRODUCT NO.

PF4MNA037T00AAAA

MODEL NO.

PF4MNA037

SERIAL NO.

2909A86950

VOLTS

208/230

MOTOR HP

1/2

MOTOR FLA

4.1

PHASE/HERTZ

1/60

TEST STATIC

0.20 IN. W.C.

REFRIGERANT 410A

DESIGN PSIG 450

DATE OF MANUFACTURING

JUL 2009

APPROVED ACCESSORIES

KFCEH**01C05

KFCEH**01N10

KFCEH**01315

KFCEH**01N08

KFCEH**01C10

KFCEH**01F20

KFCEH**01C03

KFCEH**01F15

KFCEH**01C20

KFCEH**01N05

KFCEH**01N09

KFCEH**01C15

** - NUMERIC



ELECTRICAL INFORMATION FOR THIS UNIT
 APPLIED ELECTRICAL HEATERS APPLY ELECTRICAL INFORMATION
 CAPACITY 5.1