

9894 CRAVENS CAMP RD.
 SILSBEE, TX 77656
 PAYMENT DUE ON RECEIPT
 (409) 385-4506 / FAX: (409) 385-7611

EXPIRATION DATE 29-DEC-2023
 TECHNICIAN MARK GONZALES
 E. DEWAYNE ANDERSON
 INSTALLER #0S0029094
 AMANDA ANDERSON LOWE
 OSSF MAINTENANCE PROVIDER #MP 0000688

4769

CUSTOMER NEIL & KATHERINE SMITH SYSTEM TYPE JET
 PROPERTY ADDRESS 3139 FM 1406 MAINTENANCE AGREEMENT
 CITY / STATE / ZIP WINNIE, TX 77665 EXPIRATION DATE 29-MAY-2024
 TELEPHONE NUMBER 409-732-7305 PERMIT # _____

MAINTENANCE & INSPECTION

OPERATIONAL INOPERATIVE

AERATOR / BLOWER

-
-
-

- BACK PRESSURE TEST
- DIFFUSER OPERATION
- FILTER

IN TANK AERATOR
IN PERFECT WORKING
ORDER

ANTS: ANTS AROUND AN AIR PUMP CAN CORRODE
 THE AIR PUMP AND VOID ANY WARRANTY

DISINFECTION DEVICE / CHLORINE

-
-
-

- TEST FOR CHLORINE RESIDUAL CHLORINE FEED TUBES
- CLEAN & ADJUST CHLORINATOR Full of REQUIRED QTY
- ACCESS PORTS SECURED AFTER MAINTENANCE OF TABS

SWIMMING POOL CHLORINE: SWIMMING POOL CHLORINE IS DANGEROUS IN AN ENCLOSED SPACE DUE TO THE CHLORINE GASSES PRODUCED / DUE TO THE DANGERS, THE USE OF SWIMMING POOL TABLETS HAS BEEN DEEMED DANGEROUS AND ILLEGAL TO USE IN THE TREATMENT OF ON-SITE SEWAGE FACILITIES BY THE EPA AND THE TCEQ.

DISTRIBUTION SYSTEM

-

SPRAYFIELD / DRIP (CIRCLE ONE)

EFFLUENT PUMP
AND SPRAY FIELD

EFFLUENT QUALITY INSPECTION

-
-
-

- EXAMINATION OF VISUAL COLOR CLEAR & CLEAR
- SLUDGE LEVEL 2 INCHES
- ODOR NO ODOR

IN PERFECT WORKING ORDER

QUANTITY	UNIT	DESCRIPTION	UNIT PRICE	TOTAL PRICE
<u>7 ea</u>		<u>CHLORINE TABS added</u>	<u>included</u> <u>N/C</u>	<u>Ø</u>
<p><u>SYSTEM IN 100% PERFECT & EFFICIENT</u> <u>OPERATION CONDITION</u> <u>BEST REGARDS</u> <u>- MARK -</u></p>				