

**Invoice**

SOLD TO <i>James Dickel</i>		SHIPPED TO <b>Limestone Water Well Drilling</b>		VIA
ADDRESS <i>275 PR 0387 A</i>		ADDRESS <b>2300 LCR 760</b>		
CITY, STATE, ZIP <i>Donett, TX</i>		CITY, STATE, ZIP <b>Groesbeck, TX 76642</b>		
CUSTOMER ORDER NO. <i>430-216-3273</i>	SOLD BY	TERMS <i>Estimate</i>	F.O.B.	DATE <i>7-11-22</i>

QTY	DESCRIPTION	UNIT PRICE	TOTAL
315	Drilling	-75	41800.00
360	Casing 1 1/2" sch 17	-45	2340.00
60	Screen		1450.00
	Gravel packing & cementing		1600.00
	Water & well development		1100.00
3 hp	pump / motor		2150.00
3 hp	control box deluxe		400.00
240'	1 1/2" sch 20 pump pipe		960.00
250'	1 1/2" jacketed pump wire		750.00
90 gal	pressure tank		890.00
	fitting package w/ brace		700.00
			\$ 17,010.00
			- 8500.00
			<u>8510.00</u>
	log & info		120.00
	Red Box Consulting LLC		\$ 8420.00
	320 614 60257		

Regulated by the Texas Department of  
Licensing and Regulation  
P.O. Box 12157 Austin, TX 78711  
1-800-803-9202 (512)-463-7880  
www.tdlr.texas.gov

*PD*  
*Call 4535*

## STATE OF TEXAS WELL REPORT for Tracking #621969

Owner: <b>Mary Rickard</b>	Owner Well #: <b>1</b>
Address: <b>273 PR 5887 A Jewett, TX 75846</b>	Grid #: <b>39-38-8</b>
Well Location: <b>TBD PR 5885 Jewett, TX 75846</b>	Latitude: <b>31° 24' 38.78" N</b>
Well County: <b>Limestone</b>	Longitude: <b>096° 18' 37.93" W</b>
	Elevation: <b>444 ft. above sea level</b>
Type of Work: <b>New Well</b>	
	Proposed Use: <b>Stock</b>

Drilling Start Date: **9/20/2022**      Drilling End Date: **9/20/2022**

	<i>Diameter (in.)</i>	<i>Top Depth (ft.)</i>	<i>Bottom Depth (ft.)</i>
Borehole:	<b>8.75</b>	<b>0</b>	<b>315</b>

Drilling Method: **Mud (Hydraulic) Rotary**

Borehole Completion: **Filter Packed**

	<i>Top Depth (ft.)</i>	<i>Bottom Depth (ft.)</i>	<i>Filter Material</i>	<i>Size</i>
Filter Pack Intervals:	<b>245</b>	<b>315</b>	<b>Gravel</b>	<b>12/20</b>

	<i>Top Depth (ft.)</i>	<i>Bottom Depth (ft.)</i>	<i>Description (number of sacks &amp; material)</i>
Annular Seal Data:	<b>0</b>	<b>20</b>	<b>Concrete 12 Bags/Sacks</b>

Seal Method: **Hand Mixed**

Sealed By: **Driller**

Distance to Property Line (ft.): **50+**

Distance to Septic Field or other concentrated contamination (ft.): **na**

Distance to Septic Tank (ft.): **na**

Method of Verification: **step**

Surface Completion: <b>Surface Sleeve Installed</b>	<b>Surface Completion by Driller</b>
---	--------------------------------------

Water Level: **92 ft. below land surface on 2022-10-04**      Measurement Method: **Sonic/Radar**

Packers: **No Data**

Type of Pump: **Submersible**      Pump Depth (ft.): **240**

Well Tests: **Jetted**      **Yield: 40 GPM after 4 hours, no drawdown specified**



Water Quality: **Strata Depth (ft.)** 230 - 315 **Water Type** good

Chemical Analysis Made: **No**

Did the driller knowingly penetrate any strata which contained injurious constituents?: **No**

Certification Data: The driller certified that the driller drilled this well (or the well was drilled under the driller's direct supervision) and that each and all of the statements herein are true and correct. The driller understood that failure to complete the required items will result in the report(s) being returned for completion and resubmittal.

Company Information: **Limestone Water Well Drilling**  
**268 PR 5762C**  
**Groesbeck, TX 76642**

Driller Name: **Clint Winstead** License Number: **59913**

Apprentice Name: **Justin Duke** Apprentice Number: **60629**

Comments: **No Data**

Lithology:  
**DESCRIPTION & COLOR OF FORMATION MATERIAL**

Top (ft.)	Bottom (ft.)	Description
0	1	clay tan
1	4	clay orange
4	7	rock
7	12	sand orange
12	18	rock
18	29	clay gray
29	35	sand gray
35	97	clay gray
97	114	sand gray
114	150	clay gray
150	190	sand gray
190	205	clay gray
205	220	sand gray
220	230	clay gray
230	250	sand gray
250	260	clay gray
260	315	sand gray

Casing:  
**BLANK PIPE & WELL SCREEN DATA**

Dia (in.)	Type	Material	Sch./Gage	Top (ft.)	Bottom (ft.)
4.5	Blank	New Plastic (PVC)	sdr 17	0	255
4.5	Screen	New Plastic (PVC)	sdr 17 0.020	255	315

---

**IMPORTANT NOTICE FOR PERSONS HAVING WELLS DRILLED CONCERNING CONFIDENTIALITY**

TEX. OCC. CODE Title 12, Chapter 1901.251, authorizes the owner (owner or the person for whom the well was drilled) to keep information in Well Reports confidential. The Department shall hold the contents of the well log confidential and not a matter of public record if it receives, by certified mail, a written request to do so from the owner.

Please include the report's Tracking Number on your written request.

**Texas Department of Licensing and Regulation  
P.O. Box 12157  
Austin, TX 78711  
(512) 334-5540**

PH 8.0

TDS 247 ppm

MANGANESE < .1 mg/L

HARDNESS 7 grains/gal

HARDNESS 120 ppm

SULFATE 0 mg/L

H<sub>2</sub>S NEG.

COPPER 0 ppm

LEAD NEG.

ALKALINITY 180 ppm

CHLORINE ~~0~~

NITROGEN ~~0~~

COPPER ~~0~~

NITRITE ~~0~~

IRON < .3 ppm

PESTICIDE NEG.

COLIFORM BACTERIA NEG.



Easy Well Water Test Kit  
Pro + Bacteria, Lead,  
Pesticide

### EASY WELL WATER TEST KIT INSTRUCTIONS

*Professional results in your own home*

#### PH SCALE

